



Evergy
1200 Main Street
Kansas City
Missouri 64105
Evergy.com

To: Jared Morrison, Director
Waste and Water Programs

Project:
Liner Design Criteria
La Cygne Upper AQC Impoundment

From:
Jay Martin, P.E.
Evergy

Memorandum

Subject: La Cygne Upper AQC Impoundment Liner Design Criteria

CCR Unit Status and Regulatory Explanation:

The La Cygne Generating Station Upper AQC Impoundment is subject to the requirements of §257.71 which addresses the requirements for liner documentation for CCR surface impoundments. A surface impoundment is considered a “lined” surface impoundment if constructed with:

- i. A liner consisting of a minimum of two feet of compacted soil with a hydraulic conductivity of no more than 1×10^{-7} cm/sec;
- ii. A composite liner that meets the requirements of §257.70(b); or
- iii. An alternative composite liner that meets the requirements of §257.70(c).

The La Cygne Upper AQC Impoundment is considered unlined primarily due to the lack of documentation supporting the “as built” clay liner materials, therefore is considered an unlined CCR surface impoundment.

